

LICENCE

No. 19204

Issued to:
Applicant:
Ebion Kablo Sanayii Tic. A.S.
Haci Eyüplü Mah. 3128 Sok. No.7
20195 UCLER / DENIZLI
Turkey

Licensee:
Ebion Kablo Sanayii Tic. A.S.
Haci Eyüplü Mah. 3128 Sok. No.7
20195 UCLER / DENIZLI
Turkey



Product : cables for fixed wiring
Trade name(s) : EBION KABLO
Type(s)/model(s) : EXVB-F2


The product and any acceptable variation thereto is specified in the annex to this licence and the documents therein referred to.

SGS CEBEC hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard specified in annex
- an inspection of the production location
- a certification agreement with the number 1512

SGS CEBEC hereby grants the right to use the CEBEC certification mark
The CEBEC certification mark may be applied to the product as specified in this licence for the duration of the CEBEC certification agreement and under the conditions of the CEBEC certification agreement.

This licence is issued on: 20/11/2014


ir. C. Lana,
Certification Manager

© Only integral publication of this certificate, including the annex, is allowed
This certificate is only valid combined with the publication on the following web address: www.sgs.com/ee



SGS Belgium NV-Division SGS CEBEC
Business Riverside Park
Bid Internationalelaan 55 Build. D
B-1070 Brussels
Tel.+32(0)2 556 00 20 Fax.+32(0)2 556 00 36

This certificate is issued by the company under its General Conditions for Certification Services accessible at http://www.sgs.com/terms_and_conditions.htm. Attention is drawn to the limitations of liability defined therein and in the Test Report herein mentioned which findings are reflected in this Certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	cables for fixed wiring
Trade name(s)	:	EBION KABLO
Type(s)/Model(s)	:	EXVB-F2
description	:	cable with copper conductors, unarmoured, XLPE insulated and PVC sheathed
rated voltage U ₀ /U	:	0.6/1 kV
number of conductors	:	1, 2, 3, 4, 5 and 4 + 1 with reduced section according to table 5A
Fire propagation	:	without fire propagation (belgian characteristic F2)
cross-sectional area(s)	:	1.5 to 500 mm ²

TESTS

Test requirements

NBN HD 603:2007/Partie 5 - Section 5-A

Test results

The test results are laid down in certification file ref. 600883/02

Remarks


This certificate is based on test reports ref.600883.02a, 600883.02b & 600883.02c

Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 20/11/2014

Department Manager, :
Product Certification : 2014-11-20

Certification Manager : 

FACTORY LOCATION(S)

Ebion Kablo Sanayii Tic. A.S.
Haci Eyüplü Mah. 3128 Sok. No.7
20195 UCLER / DENIZLI
Turkey