

SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	:	cables for fixed wiring
Trade name(s)	:	EBION KABLO
Type(s)/Model(s)	:	XVB-F2
description	:	cable with copper conductors, unarmoured, XLPE insulated and PVC sheathed
rated voltage U _o /U	:	0.6/1 kV
number of conductors	:	1, 2, 3, 4, 5 and > 5 cores according to table 2G
Fire propagation	:	without fire propagation (Belgian characteristic F2)
cross-sectional area(s)	:	1.5 to 300 mm ²

TESTS

Test requirements

NBN HD 604:1995 + A4:2012

Test results

The test results are laid down in certification file ref 600883/01

Remarks

This certificate is based on test reports ref. 600883.01a, 600883.01b and 600883.01c


Conclusion

The examination proved that all test requirements were met.

Checked by, project leader : Zanutto Luigi - 20/10/2014

Department Manager, :
Product Certification :

Certification Manager :



Zanutto 2014-10-20

FACTORY LOCATION(S)

Ebion Kablo Sanayii Tic. A.S.
Haci Eyüplü Mah. 3128 Sok. No.7, UCLER / DENIZLI, Turkey