

Product Certification Schedule

Schedule No:	191/001/050
Licensee:	EBION KABLO SANAYI TICARET ANONIM SIRKETI, HACI EYUPLU MAH., 3128 SOK. NO: 7 UCLER, DENIZLI, TURKEY
Factory:	EBION KABLO SANAYI TICARET ANONIM SIRKETI, HACI EYUPLU MAH., 3128 SOK. NO: 7 UCLER, DENIZLI, TURKEY
Specification:	BS 6724:1997 & A3:2008 - Electric cables - Thermosetting insulated, armoured cables for voltages of 600/1000V and 1900/3300V having low emission of smoke and corrosive gases when affected by fire
Type of Cable:	Tables 6, 8, 10 and 13 - Two-core, three-core, four-core and five-core 600/1000V cables with stranded copper conductors
HAR Document:	Not applicable
HAR Specification:	Not applicable
Range of Approval:	1.5sqmm to 300sqmm nominal cross-sectional area of conductors inclusive. Two-core to four-core inclusive. 1.5sqmm to 70sqmm nominal cross-sectional area of conductors inclusive. five-core. Sheath - LTS1. Insulation - GP8.
Origin Thread:	Not applicable
Origin Mark:	ebion kablo or EB or EUROKAB

PERMISSIBLE MARKS



BASEC

YELLOW
ACETATE
THREAD

Please refer to the BASEC Product Certification Requirements

Expiry Date: 05/09/2018

Signed for and on behalf of the British Approvals Service for Cables

Date 01/09/2015

This Certificate and Schedule(s) remains the property of BASEC, and shall be returned when required.



004